

Reaction to fire



The applicant: **ELITIS, S.A.**  
2 BIS RUE JEAN RODIER  
31400 TOULOUSE-FRANCIA

is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the report N° 2017AN1062



**CLASSIFICATION OF REACTION TO FIRE OF:  
CONSTRUCTION PRODUCTS**

**N° 17AN1062**

The sample reference:

**“ HPC Métallique ”**

has been tested according to the standards UNE-EN ISO 11925-2:2011 (equivalent to EN ISO 11925-2:2010) and UNE-EN 13823:2012+A1:2016 (equivalent to EN 13823:2010+A1:2014). The classification according to standard UNE-EN 13501-1:2007+A1:2010 (equivalent to EN 13501-1:2007+A1:2010) is:

**“B-s1,d0”**

Alcoy, May 11th 2017



**Celia Dolça**  
HEAD OF FIRE BEHAVIOUR LAB.