

The applicant: **ELITIS, S.A.**
2 BIS RUE JEAN RODIER
31400 TOULOUSE-FRANCIA

is authorized to place the label "Classification of Reaction to Fire of Construction Products " according to the report N° 2021AN1359



aitex
textile research institute

**CLASSIFICATION OF REACTION TO FIRE OF:
CONSTRUCTION PRODUCTS**

N° 21AN1359

The sample reference:

“ VESTIAIRE MASCULIN RM 1016”

has been tested according to the standards EN ISO 11925-2:2020 and EN 13823:2010+A1:2014. The classification according to standard EN 13501-1:2018 is:

“D-s1,d0”

Alcoy, June 25th 2021.

Celia Dolça
HEAD OF FIRE BEHAVIOUR LAB.

