

The applicant: **ELITIS, S.A.**
2 BIS RUE JEAN RODIER
31400 TOULOUSE-FRANCIA

is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the report N° 2017AN2542



aitex
textile research institute

**CLASSIFICATION OF REACTION TO FIRE OF:
CONSTRUCTION PRODUCTS**

N° 17AN2542

The sample reference:

"DOMINO (RM 250, RM 251, RM 252, RM 253, RM 254, RM 255, RM 256 and RM 257)"

has been tested according to the standards UNE-EN ISO 11925-2:2011 (equivalent to EN ISO 11925-2:2010) and UNE-EN 13823:2012+A1:2016 (equivalent to EN 13823:2010+A1:2014). The classification according to standard UNE-EN 13501-1:2007+A1:2010 (equivalent to EN 13501-1:2007+A1:2010) is:

"B-s1,d0"

Alcoy, November 21st 2017.



Celia Dolça
HEAD OF FIRE BEHAVIOUR LAB.

