



aitex

textile research institute
Plaza Emilio Sala 1 - 1º
E-03801 Alcoy (Alicante)

PRODUCT-TYPE TEST

The applicant:

ELITIS, S.A.
2 BIS RUE JEAN RODIER
31400 TOULOUSE-FRANCIA

In compliance with the Regulation (UE) No. 305/2011 laying down harmonised conditions for the marketing of construction products, has performed reaction to fire type testing in:



aitex
textile research institute

Notified Testing Laboratory No. 0161

Document No. 15AN2471

Attending the set conditions for the CE marking detailed at Annex ZA of the harmonised product standard **EN 15102:2007+A1:2011**, the notified laboratory declares on its classification report No. 2015AN2471 that the **decorative wall covering** referenced as:

“RM 663 EPURE”

has been tested according to the requirements described at product standard, achieving the EN 13501-1:2007+A1:2009 classification

“C-s1,d0”

Product, tests and field of application details are stated on the annex A of this document.

Alcoy, November 12nd 2015.

Raquel Muñoz González
CHIEF OF INNOVATION AREA


Jordi Ferri Pascual
HEAD OF FIRE DEPARTMENT