

**PRODUCT-TYPE TEST**

The applicant:

**ELITIS, S.A.**  
2 BIS RUE JEAN RODIER  
31400 TOULOUSE-FRANCIA

In compliance with the Regulation (UE) No. 305/2011 laying down harmonized conditions for the marketing of construction products, has performed reaction to fire type testing in:



**aitex**  
textile research institute

**Notified Testing Laboratory No. 0161**

**Document No. 16AN1948**

Attending the set conditions for the CE marking detailed at Annex ZA of the harmonized product standard **EN 15102:2007+A1:2011**, the notified laboratory declares on its classification report No. 2016AN1948 that the **decorative wall covering** referenced as:

**“RM 672”**

has been tested according to the requirements described at product standard, achieving the EN 13501-1:2007+A1:2009 classification

**“B-s1,d0”**

Product, tests and field of application details are stated on the annex A of this document.

Alcoy, September 22nd 2016.

**Raquel Muñoz González**  
CHIEF OF INNOVATION AREA

