

The applicant:

ELITIS, S.A.
2 BIS RUE JEAN RODIER
31400 TOULOUSE - FRANCIA

is authorized to place the label "Certificate of Reaction to Fire of Construction Products" according to the report Nº 2010AN3956



aitex

instituto tecnológico textil

**CERTIFICATE OF FIRE
BEHAVIOUR OF:**

CONSTRUCTION PRODUCTS

Nº 10AN3956

The ceiling covering gamma referenced as

"PRECIOUS WALLS"

has been tested according to the standards UNE EN ISO 11925-2:2002 and UNE EN 13823:2002. The classification according to standard UNE EN 13501-1:2007 is:

"B_{s1,d0}"



The applicant:

ELITIS, S.A.
2 BIS RUE JEAN RODIER
31400 TOULOUSE - FRANCIA

**CERTIFICATE OF FIRE
BEHAVIOUR OF:
CONSTRUCTION PRODUCTS
Nº 10AN3956**

The gamma is formed by 20 articles referenced:

- | | |
|-------------|-------------|
| - RM 708 01 | - RM 710 02 |
| - RM 708 12 | - RM 710 10 |
| - RM 708 31 | - RM 710 21 |
| - RM 708 65 | - RM 710 33 |
| - RM 708 70 | - RM 710 45 |
| - RM 708 71 | - RM 710 52 |
| - RM 708 73 | - RM 710 70 |
| - RM 708 81 | - RM 710 77 |
| - RM 708 92 | - RM 710 82 |
| - RM 708 95 | - RM 710 |

Alcoy, September 09th 2010



Raquel Muñoz González
CHIEF OF LABORATORIES AREA

