

# TYPE TEST

The applicant: **ELITIS, S.A.**  
2 BIS RUE JEAN RODIER  
31400 TOULOUSE-FRANCIA

Attending the described tasks for the verification of conformity system 3 and the detailed features at harmonised product standard UNE-EN 15102:2008+A1:2012 V2



**aitex**  
textile research institute

**Notified Body No. 0161**

**Nº 14AN0247**

Declares at classification report no. 2014AN0247 that the decorative wall covering referenced as:

**"ECLAT RM 881"**

have been tested following the mentioned harmonised product standard requirements, being classified according to UNE-EN 13501-1 as:


**"B-s1,d0"**

Valid for the conformity declaration required at clause ZA.2.2 or the harmonised product standard.

Alcoy, January 29th 2014.



**Raquel Muñoz González**  
CHIEF OF INNOVATION AREA



**Jordi Ferri Pascual**  
HEAD OF FIRE DEPARTMENT

