



The applicant: **ELITIS, SAS**  
2 BIS RUE JEAN RODIER  
31400 TOULOUSE-FRANCIA

is authorized to place the label "Classification of Reaction to Fire of Construction Products " according to the report N° 2018AN2592



**aitex**  
textile research institute

**CLASSIFICATION OF REACTION TO FIRE OF:  
CONSTRUCTION PRODUCTS**

**N° 18AN2592**

The sample reference:

**“POP (RM 893, RM 894, RM 895, RM 896, RM 897,  
RM 898)”**

has been tested according to the standards EN ISO 11925-2:2010 and EN 13823:2010+A1:2014. The classification according to standard EN 13501-1:2007+A1:2010 is:

**“B-s1,d0”**

Alcoy, September 19th 2018.

---

**Celia Dolça**  
HEAD OF FIRE BEHAVIOUR LAB.