



The applicant: **ELITIS, SAS**  
2 BIS RUE JEAN RODIER  
FR-31400 TOULOUSE

is authorized to place the label "Classification of Reaction to Fire of Construction Products " according to the report N° 2020AN1472



**aitex**  
textile research institute

**CLASSIFICATION OF REACTION TO FIRE OF:  
CONSTRUCTION PRODUCTS**

**N° 20AN1472**

The sample reference:

**“ESSENCE DE LIEGE”**

has been tested according to the standards EN ISO 11925-2:2010 and EN 13823:2010+A1:2014. The classification according to standard EN 13501-1:2018 is:

**“D-s1,d0”**

Alcoy, September 25th 2020.

**Celia Dolça**  
HEAD OF FIRE BEHAVIOUR LAB.