

TYPE TEST

The applicant: **ELITIS, S.A.**
2 BIS RUE JEAN RODIER
31400 TOULOUSE-FRANCIA

Attending the described tasks for the verification of conformity system 3 and the detailed features at harmonised product standard UNE-EN 15102:2008+A1:2012 V2



Notified Body No. 0161

Nº 13AN0272

Declares at classification report no. 2013AN0272 that the decorative wall covering referenced as:

**"PLEATS TP 170, TP 171, TP 172, TP 180,
TP 181, TP 182, TP 183, TP 184, TP 190,
TP 200"**

have been tested following the mentioned harmonised product standard requirements, being classified according to UNE-EN 13501-1 as:

"B-s1,d0"

Valid for the conformity declaration required at clause ZA.2.2 or the harmonised product standard.
Alcoy, January 31st 2013.



Raquel Muñoz González
CHIEF OF INNOVATION AREA



Jordi Ferri Pascual
HEAD OF FIRE DEPARTMENT