

The applicant: **ELITIS, S.A.**
2 BIS RUE JEAN RODIER
31400 TOULOUSE-FRANCIA

is authorized to place the label "Classification of Reaction to Fire of Construction Products " according to the report N° 2020AN1466



aitex
textile research institute

**CLASSIFICATION OF REACTION TO FIRE OF:
CONSTRUCTION PRODUCTS**

N° 20AN1466

The sample reference:

“LES PETITES HISTOIRES”

has been tested according to the standards EN ISO 11925-2:2010 and EN 13823:2010+A1:2014. The classification according to standard EN 13501-1:2018 is:

“B-s1,d0”

Alcoy, September 29th 2020.

Celia Dolça
HEAD OF FIRE BEHAVIOUR LAB.

