

PRODUCT-TYPE TEST

The applicant:

ELITIS, S.A.
2 BIS RUE JEAN RODIER
31400 TOULOUSE-FRANCIA

In compliance with the Regulation (UE) No. 305/2011 laying down harmonised conditions for the marketing of construction products, has performed reaction to fire type testing in:



aitex
textile research institute

Notified Testing Laboratory No. 0161

Document No. 16AN1438

Attending the set conditions for the CE marking detailed at Annex ZA of the harmonised product standard EN 15102:2007+A1:2011, the notified laboratory declares on its classification report No. 2016AN1438 that the decorative wall covering referenced as:

"RAFFIA VP 601 / VP 605 / VP 603"

has been tested according to the requirements described at product standard, achieving the EN 13501-1:2007+A1:2009 classification

"B-s2,d0"

Product, tests and field of application details are stated on the annex A of this document.

Alcoy, July 5th 2016.



Raquel Muñoz Gonzalez
CHIEF OF INNOVATION AREA

