

The applicant:

ELITIS, S.A.
2 BIS RUE JEAN RODIER
31400 TOULOUSE - FRANCIA

is authorized to place the label "Certificate of Reaction to Fire of Construction Products" according to the report N° 2010AN3955



aitex

instituto tecnológico textil

**CERTIFICATE OF FIRE
BEHAVIOUR OF:**

CONSTRUCTION PRODUCTS

N° 10AN3955



The ceiling covering gamma referenced as

"CUIRS LEATHERS"

has been tested according to the standards UNE EN ISO 11925-2:2002 and UNE EN 13823:2002. The classification according to standard UNE EN 13501-1:2007 is:

"C_{s2,d0}"

The applicant:

ELITIS, S.A.
2 BIS RUE JEAN RODIER
31400 TOULOUSE - FRANCIA

**CERTIFICATE OF FIRE
BEHAVIOUR OF:**

CONSTRUCTION PRODUCTS

Nº 10AN3955

The gamma is formed by 47 articles referenced:

- VP 690 01 - VP 690 02 - VP 690 03 - VP 690 04 - VP 690 05
- VP 690 06 - VP 690 07 - VP 690 08 - VP 690 09 - VP 690 10
- VP 690 11 - VP 690 12 - VP 690 13 - VP 690 14 - VP 690 15
- VP 690 16 - VP 690 17 - VP 690 18 - VP 690 19 - VP 690 20
- VP 691 01 - VP 691 03 - VP 691 08 - VP 691 12 - VP 691 14
- VP 691 15 - VP 692 02 - VP 692 05 - VP 692 09 - VP 692 10
- VP 693 03 - VP 693 07 - VP 693 16 - VP 693 17 - VP 694 05
- VP 694 09 - VP 694 11 - VP 694 12 - VP 696 06 - VP 696 08
- VP 696 09 - VP 696 15 - VP 697 03 - VP 697 10 - VP 697 13
- VP 697 15 - VP 697 16

Alcoy, ASeptember09th 2010

Raquel Muñoz González
CHIEF OF LABORATORIES AREA