



The applicant: **ELITIS, S.A.**
2 BIS RUE JEAN RODIER
31400 TOULOUSE-FRANCIA

Is authorized to place the label "Classification of Reaction to Fire of Construction Products " according to the report N° 2018AN1924



aitex
textile research institute

**CLASSIFICATION OF REACTION TO FIRE OF:
CONSTRUCTION PRODUCTS**

N° 18AN1924

The sample reference:

“ VP715 VP716 VP719 VP720 VP722”

has been tested according to the standards EN ISO 11925-2:2010 and EN 13823:2010+A1:2014. The classification according to standard EN 13501-1:2007+A1:2009 is:

“B-s2,d0”

Alcoy, July 9th 2016.

Celia Dolça
HEAD OF FIRE BEHAVIOUR LAB.