



The applicant: **ELITIS, SAS**  
2 BIS RUE JEAN RODIER  
31400 TOULOUSE-FRANCIA

is authorized to place the label "Classification of Reaction to Fire of Construction Products " according to the report N° 2018AN2596



**CLASSIFICATION OF REACTION TO FIRE OF:  
CONSTRUCTION PRODUCTS**

**N° 18AN2596**

The sample reference:

**“OPENING (VP 723 + VP 724 + VP 727)”**

has been tested according to the standards EN ISO 11925-2:2010 and EN 13823:2010+A1:2014. The classification according to standard EN 13501-1:2007+A1:2010 is:

**“B-s1,d0”**

Alcoy, September 20th 2018.

**Celia Dolça**  
HEAD OF FIRE BEHAVIOUR LAB.