

PRODUCT-TYPE TEST

The applicant:

ELITIS, S.A.
2 BIS RUE JEAN RODIER
31400 TOULOUSE-FRANCIA

In compliance with the Regulation (UE) No 305/2011 laying down harmonized conditions for the marketing of construction products, has performed reaction to fire type testing in:



Notified Testing Laboratory No. 0161

Document No. 16AN2449

Attending the set conditions for the CE marking detailed at Annex ZA of the harmonized product standard **EN 15102:2007+A1:2011**, the notified laboratory declares on its classification report No. 2016AN2449 that the **decorative wall covering** referenced as:

“TALAMONE”

has been tested according to the requirements described at product standard, achieving the EN 13501-1:2007+A1:2009 classification

“C-s2,d0”

Product, tests and field of application details are stated on the annex A of this document.

Alcoy, November 14th 2016



Raquel Muñoz González
CHIEF OF INNOVATION AREA

