

The applicant:

**ELITIS, S.A.**  
2 BIS RUE JEAN RODIER  
31400 TOULOUSE-FRANCIA

In compliance with the Regulation (UE) No. 305/2011 laying down harmonised conditions for the marketing of construction products, has performed reaction to fire type testing in:



**Notified Testing Laboratory No. 0161**

**Document No. 15AN2468**

Attending the set conditions for the CE marking detailed at Annex ZA of the harmonised product standard **EN 15102:2007+A1:2011**, the notified laboratory declares on its classification report No. 2015AN2468 that the **decorative wall covering** referenced as:

**“NOMADES”**

has been tested according to the requirements described at product standard, achieving the EN 13501-1:2007+A1:2009 classification


**“B-s2,d0”**

Product, tests and field of application details are stated on the annex A of this document.

Alcoy, November 16th 2015.



**Raquel Muñoz González**  
CHIEF OF INNOVATION AREA



**Jordi Ferri Pascual**  
HEAD OF FIRE DEPARTMENT

